



325 W. 18th St. Suite 3
Cheyenne, WY 82002
307.514.4575

225 W. Yellowstone Ave. Suite 4
Cody, WY 82414
307.587.8646

4020 Dewar Dr. Suite A Rock
Springs, WY 82901
307.352.2954

1174 Stoneridge Dr. Suite 213
Bozeman, MT 59718
406.219.5992

ADDENDUM FOUR

Project: Memorial Hospital of Sweetwater County Oncology Suite Renovation **Architect's Project No:** 2159

Owner: Memorial Hospital of Sweetwater County
1200 College Drive
Rock Springs, WY 82901 **Addendum Number:** 004 (Four)

Bid Date: April 13, 2013 **Time:** 1:30 pm **Addendum Date:** April 11, 2023

IT IS INTENDED THAT BIDS SUBMITTED ARE BASED ON THE INCLUSION OF ALL ADDENDA. PLEASE ATTACH ALL ADDENDA TO THE SPECIFICATIONS AND ACKNOWLEDGE RECEIPT OF SAME IN THE DESIGNATED PLACE ON THE BID FORM.

PART ONE - SUBSTITUTIONS:

The following manufacturers are accepted as substitutes. The substitute product used on this Project does not relieve the manufacturer and his installer from the intent, responsibilities, and requirements stipulated by the specifications, and the minimum standards implied by originally specified manufacturer.

Any modifications to the work necessary to properly install, build in or otherwise make substituted items or equipment functional and useable shall be at the Contractor's expense.

APPROVALS: NONE

PART TWO - SPECIFICATIONS: NONE.

PART THREE - DRAWINGS: NONE.

PART FOUR - MISCELLANEOUS:

Clarifications:

1. Scrub Sink:
 - a. Owner preferred Basis-of-Design is as follows:
 - i. Elkay Stainless Steel 30" x 23" x 26" Wall Hung Single Bowl Surgeon Scrub Sink Kit Model EWSF13026KWC
 - ii. Bradley Sing-Down Halo Eye/Face Wash Unit, Model S19274HD/R. Coordinate Length with Sink. Mount 6.5" from centerline of sink on lefthand side and 1.5" from lip of basin. Coordinate final mounting location.
2. Automatic Sliding Doors:
 - a. Controls shall be programmed/installed so as to create an interlock within the Ante Room. One automatic sliding door cannot open until the other is closed.

PART FIVE - PLAN HOLDERS LIST: Per Host Bidding Site: Quest CDN

END OF ADDENDUM